



RS 9C/001-2014

Issued December 2013

**EUROVENT RATING STANDARD
for
COOLING TOWERS**

RS 9C/001-2014

Issued December 2013
Supersedes RS 9C/001-2010

Editing:	Ian BUTLER	5 December 2013
Checking:	Jean FOURCROY	13 December 2013
Approval:	Compliance Committee CT CPPC	7 January 2014 23 December 2013
Comes into effect from:		21 January 2014

Modifications as against last version:

Nb	Modifications	Section	Page
1	Include Open & Closed Circuit.....	I	4
2	Clarify CTI document CTI STD201RS or OM	Various	

This document is strictly reserved for use in the Certification Programmes of Eurovent Certita Certification. Reproduction or translation of any part of the document is forbidden without written permission from Eurovent Certita Certification.

Published by Eurovent Certita Certification SAS
 53 rue de Turbigo
 75003 Paris, FRANCE

Tel: + 33 1 49 96 69 80

Fax: + 33 1 49 96 45 10

E-mail: i.butler@eurovent-certification.com

TABLE of CONTENTS

I. PURPOSE	4
II. SCOPE	4
III. DEFINITIONS	4
IV. TESTING REQUIREMENTS	4
V. RATING REQUIREMENTS	4
VI. CERTIFIED CHARACTERISTICS	4
VII. TOLERANCES	4

I. PURPOSE

The purpose of this Rating Standard is to establish definitions and specifications for testing and rating of Open & Closed-Circuit series Cooling Towers, in accordance with Operational Manual OM-4.

II. SCOPE

The Certification Programme for Cooling Towers within Eurovent Certita Certification applies to the range of conditions and other qualifications as defined in CTI STD-201 OM and Operational Manual OM-4.

III. DEFINITIONS

Definitions shall be per CTI STD-201 OM.

IV. TESTING REQUIREMENTS

Testing requirements shall be as required to meet and maintain certification by CTI STD-201 RS and Eurovent Certita Certification OM-4.

V. RATING REQUIREMENTS

Rating requirements shall be per CTI STD-201 RS.

VI. CERTIFIED CHARACTERISTICS

Certified Characteristics shall be per CTI STD-201 RS.

VII. TOLERANCES

The testing tolerances shall be per CTI STD-201 RS. The tolerances of the data of record are given in the OM-4.